

RESISTANCE @ $+25^{\circ}\text{C} = 10,000 \ \Omega \pm 1\%$ RESISTANCE/TEMPERATURE CURVE = "J" TEMPERATURE COEFFICIENT @ $+25^{\circ}\text{C} = -4.4\%$ /°C NOMINAL BETA " β " (0 TO $+50^{\circ}\text{C}$) = 3,892°K NOMINAL MAXIMUM TEMPERATURE RATING = $+80^{\circ}\text{C}$

MOISTURE RESISTANT PROBE ASSEMBLY

SEE MANUFACTURING SPECIFICATION (LAYER 1)

NONE	RELEASE TO PRODUCTION	04/02/10	DD
REV	REVISION RECORD	DATE	APP

scale NONE	U.S. SENSOR corp.
DRAWN BY	1832 W . COLL INS AVE .
DAN DANKERT	ORANGE, CA. 92867 714-639-1000 www.ussensor.com
DATE 04/02/10	NTC THERMISTOR PROBE
REV. NONE	,
LAYER 0 OF 2	P/N USP10982